Installation & Operating Guide

LED Volumetric Recessed

WARNING RISK OF ELECTRIC SHOCK AND INJURY – Shock and injury can occur if you are exposed to electrical current or use unsafe installation practices.

- For your safety, please read all instructions and warnings prior to installation and follow these guidelines. Keep these instructions for future reference.
- Installation or service of product should be performed by a qualified, experienced electrician.
- Appropriate safety equipment must be used per local safety standards.
- Inspect product for any damage that may have occurred during shipping. Do not install damaged product.
- Before installation, make sure product application is compatible with manufacturer design recommendations.
- For use in indoor recessed ceilings only.
- **ALWAYS** disable power before installation or maintenance.
- Wiring must meet UL standards
- All electrical connections must comply with the National Electrical Code (NEC, NFPA70) as well as necessary local code.
- Do not touch LEDs
- Properly dispose of packaging



INSTALLATION:

1. Insert the fixture as required to fit through the t-grid and adjust so that it faces down. Make sure fixture is oriented to facilitate electrical splicing.

2. Remove necessary knockouts on the access plate to route input conduit. Use only connectors approved by local codes.

3. Wire the fixture according to the wiring diagram.
   - Connect the black fixture wire to the (+) LINE supply lead.
   - Connect the white fixture wire to the (-) NEUTRAL supply lead.
   - Connect the ground wire from fixture to supply ground.

If using 0-10V dimming:
- Connect the purple wire to (+)DIM lead.
- Connect the gray wire to (-)DIM lead



